

## **CHAPTER 7**

---

### **SUMMARY OF RECOMMENDED PROJECT**

**Joint Water Pollution Control Plant**

**Proposed WRP Expansions**

**Biosolids Management**

**Related Projects**

**Project Financing**

## **CHAPTER 7      SUMMARY OF RECOMMENDED PROJECT**

---

As stated in Chapter 6, Alternative 1 is the preferred project alternative. Hence, the preferred project calls for 400 mgd of secondary treatment capacity at the JWPCP, a 25 mgd expansion of the SJCWRP, and a 12.5 mgd expansion of the LCWRP.

### **7.1 JOINT WATER POLLUTION CONTROL PLANT**

#### **7.1.1 PROPOSED JWPCP TREATMENT FACILITIES**

Proposed facilities at the JWPCP were described in Chapter 6. In summary, proposed JWPCP facilities include: solids processing facilities; power generation facilities; support facilities including expanded laboratory facilities, a washwater filtration facility, and new and expanded change rooms and operator training rooms; and wastewater treatment facilities including modifications and upgrades to headworks facilities and centrate treatment facilities, expanded secondary treatment facilities including WAS thickening facilities, and improved odor control facilities. In addition, the proposed work at the JWPCP includes subsurface investigation and remediation which were also described in Chapter 6. The footprint of proposed facilities at the JWPCP is illustrated in Figure 7.1-1. Detailed design criteria for proposed JWPCP facilities are presented in Table 7.1-1.

In general, design of proposed JWPCP facilities will begin in 1995 and the design of reactors and clarifiers will be completed by December 31, 1997, construction of proposed JWPCP secondary treatment facilities will begin by April 30, 1998 and be completed by June 30, 2002, startup of JWPCP full secondary treatment facilities will commence by June 30, 2002, and the JWPCP will achieve full compliance with Section 301(b) of the CWA by December 31, 2002 as required by the Consent Decree. A more detailed schedule which presents proposed scheduling and phasing of project elements necessary to meet the general time constraints outlined above is presented in Figure 7.1-2.

**THIS PAGE INTENTIONALLY  
LEFT BLANK**

**Table 7.1-1  
 DETAILED DESIGN CRITERIA FOR PROPOSED FACILITIES AT JWPCP: 400 mgd PLANT CAPACITY  
 YEAR 2010**

Process	Capacity	Process	Capacity
<i>Plant Flow</i>		<i>Emergency Effluent Pumps</i>	
Avg [mgd]	400	Number	2
Peak Sanitary [mgd]	540	Capacity per Pump [mgd]	50
Sustained High Daily (12 hrs) [mgd]	500	Lift [ft]	40
Peak Storm [mgd]	630	Power per Pump [HP]	400
<i>Influent Wastewater Characteristics</i>		<i>Effluent Tunnels</i>	
Suspended Solids [mg/L]	530	8 Foot Tunnel	
Suspended Solids [lb/day]	1,760,000	Length [ft]	32,000
BOD [mg/L]	425	Material	Reinforced Concrete
BOD [lbs/day]	1,420,000	12 Foot Tunnel	
		Length [ft]	32,000
		Material	Reinforced Concrete
<i>Influent</i>		<i>Ocean Outfalls</i>	
Inlet Works No. 1-Pumps		No. 1	Not in Service
Number	5 (1 standby)	No. 2	
Capacity per Pump [mgd]	57.6	Inside Diameter [inches]	72
Lift [ft]	6	Total Length [ft]	7,048
Power per Pump [HP]	150	Diffuser Length [ft]	648
Inlet Works No. 1-Gravity		Avg Diffuser Depth [ft]	155
Gravity Influent [mgd]	265	Number & Diameter of Ports [inches]	40 @ 9
Inlet Works No. 2-Pumps		Spacing of Ports	2 every 24 ft.
Number	4 (1 standby)	Capacity [mgd]	106
Capacity per Pump [mgd]	78	No. 3	
Lift [ft]	6	Inside Diameter [inches]	90
Power per Pump [HP]	200	Total Length [ft]	10,300
<i>Primary Effluent Pumps</i>		Diffuser Length [ft]	2,400
Number	5 (all standby)	Avg Diffuser Depth [ft]	203
Capacity per Pump [mgd]	122	Number & Diameter of Ports [inches]	2 @ 15
Lift [ft]	33	Spacing of Ports [ft]	32 @ 7.5
Power per Pump [HP]	1,100	Capacity [mgd]	68 @ 6.5
<i>Secondary Influent Pumps</i>			24
Number	5		164
Capacity per Pump [mgd]	135		
Lift [ft]	31		
Power per Pump [HP]	1,180		
<i>Secondary Effluent Pumps</i>			
Number	5		
Capacity per Pump [mgd]	135		
Lift [ft]	33		
Power per Pump [HP]	1,000		

**Table 7.1-1  
 DETAILED DESIGN CRITERIA FOR PROPOSED FACILITIES AT JWPCP: 400 mgd PLANT CAPACITY  
 YEAR 2010 (Continued)**

Process	Capacity	Process	Capacity
<i>Ocean Outfalls (continued)</i>		<i>Preliminary Treatment (continued)</i>	
No. 4		Grit Handling Facilities	
Inside Diameter [inches]	120	Initial Separator	Vortex Classifier
Total Length [ft]	11,880	Quantity	6
Diffuser Length [ft]	4,440	Grit Concentrator	Integrated
Avg Diffuser Depth [ft]	178	Quantity	Clarifier/Conveyor
Number & Diameter of Ports [inches]	2 @ 6	Grit Storage	Covered Roll-off
	228 @ 3.6	Quantity	Bins
	176 @ 3.2	Primary Treatment	6
	112 @ 3.0	Primary Sedimentation Tanks	
	96 @ 2.75	Type	Rectangular
	96 @ 2.55	Number	52
Spacing of Ports [ft.]	32 @ 2.00	Avg Overflow Rate [gpd/ft <sup>2</sup> ]	1,250-1,690
Capacity [mgd]	6	Detention Time [hrs]	1.3
	349	Suspended Solids Removal [%]	70
<i>Preliminary Treatment</i>		Solids Conveyors	Chain and Flight
Bar Screens		Number	26
Type	Vertical bars, 1' spacing	Solids Collector Pumps	Recessed Impeller
Location	6 @ Inlet Works No. 1	Number	18
	3 @ Inlet Works No. 2		
Grinders		<i>Secondary Treatment</i>	
Type	In-line	Influent Characteristics	
Quantity	6 (all standby)	Suspended Solids [mg/L]	160
Screenings Handling Facility		Suspended Solids [lb/day]	534,000
Screenings Pump	Chopper	COD [mg/L]	460
Quantity	2	COD [lb/day]	1,535,000
Initial Dewatering	Integrated Screw Press	Biological Reactors	
Quantity	2	Number of 50 mgd Trains	8
Final Dewatering	Hydraulic Ram Press	Number of Liquid Stages per Train	4
Quantity	2	Number of Gas Stages per Train	12
Screenings Storage	Covered Roll-off Bin	Mixing	Surface Aerators
Quantity	2	Water Depth [ft]	15
Aerated Grit Chambers		Solids Recycle [%]	40
Number	6	Avg Detention Time (V/Q) [hrs]	2.5
Shape	Rectangular	Avg Detention Time (V/Q+R) [hrs]	1.8
Aeration Compressor [HP]	6 @ 150	Oxygen Generation Plants	
Detention Time [min]	5	Type	Cryogenic
Slurry Pumps	Recessed Impeller	Number of Plants	4
Quantity	12	Capacity per Plant [tons/day]	150
		Oxygen Purity	98%
		Number of Air Compressors	5
		Compressor Load [HP]	2,500
		Number of Liquid Oxygen Storage Tanks	3
		Liquid Oxygen Capacity per Tank [tons]	215

**Table 7.1-1  
DETAILED DESIGN CRITERIA FOR PROPOSED FACILITIES AT JWPCP: 400 mgd PLANT CAPACITY  
YEAR 2010 (Continued)**

Process	Capacity	Process	Capacity
<i>Secondary Treatment (continued)</i>		<i>Chlorination (continued)</i>	
Final Sedimentation Tanks		Lime Facility	
14 Foot Deep Rectangular Tanks		Number of Railcars	2
Number	104	Size [tons]	95
Length [ft]	167	Unloading Capacity [tons/hr]	30
Width [ft]	21	Lime Storage Tanks	3
Avg Overflow Rate [gpd/ft <sup>2</sup> ]	548	Storage Capacity [tons]	555
Peak Sanitary Overflow Rate [gpd/ft <sup>2</sup> ]	739	Number of Lime Slakers	2
Avg Detention Time (w/40% R) [hrs]	3.3	Capacity per Slaker [lb/hr]	5,500
16 Foot Deep Rectangular Tanks		<i>pH Control of Secondary Effluent</i>	
Number	104	Secondary Effluent Characteristics	
Length [ft]	167	Calcium Hardness [mg/L]	170
Width [ft]	21	Magnesium Hardness [mg/L]	97
Avg Overflow Rate [gpd/ft <sup>2</sup> ]	548	Alkalinity [mg/L]	251
Peak Sanitary Overflow Rate [gpd/ft <sup>2</sup> ]	739	pH	6.8
Avg Detention Time (w/40% R) [hrs]	3.7	Carbonic Acid [mg/L]	182
<i>Chlorination</i>		Lime Usage as CaO	
Chlorine Dose		Avg Dose [mg/L]	28
Avg Dose [mg/L]	10.0	Avg [ton/day]	47
Max Dose [mg/L]	17.0	Peak Sanitary [ton/day]	63
Chlorine Usage		Peak Storm [ton/day]	74
Avg Flow @ Avg Dose [lb/day]	33,000	<i>Waste Activated Sludge (WAS) Thickening</i>	
Avg Flow @ Max Dose [lb/day]	57,000	WAS Flow	
Peak Sanitary Flow @ Max Dose [lb/day]	77,000	Avg Flow [gpm]	5,600
Peak Storm Flow @ Max Dose [lb/day]	89,000	Max Flow [gpm]	8,500
Lime Usage		WAS Dry Solids Production	
Avg Flow @ Avg Dose [lb/day]	26,000	Avg Solids Load [lb/day]	550,000
Peak Storm Flow @ Max Dose [lb/day]	74,000	Max Solids Load [lb/day]	830,000
Chlorine Unloading Facility		Dissolved Air Flotation (DAF) Tanks	
Number of Railcars	6	Type	Rectangular
Size [tons]	90	Number	10
Max Flow Rate [lb/hr]	15,000	Solids Loading @ Avg Rate [lb/hr-ft <sup>2</sup> ]	5.0
Railcar Enclosure		Overflow Rate @ Avg Flow [gpm/ft <sup>2</sup> ]	1.2
Height [ft]	35	Loading Rate (w/ Recycle) [gpm/ft <sup>2</sup> ]	3.9
Length [ft]	190	Air to Solids Ratio @ Avg Flow	0.026
Number of Cars	6	Thickened WAS Pump Station	
		Number of Pumps	4
		Capacity per Pump [gpm]	800
		Pressure per Pump [psig]	80

7-5

**Table 7.1-1  
 DETAILED DESIGN CRITERIA FOR PROPOSED FACILITIES AT JWPCP: 400 mgd PLANT CAPACITY  
 YEAR 2010 (Continued)**

Process	Capacity	Process	Capacity
<b>Anaerobic Digestion</b>		<b>Solids Dewatering (continued)</b>	
Primary Solids Flow [mgd]	4.6	Rotary Screens	
Primary Solids Concentration [% TS]	3.2	Number	14
Primary Solids [ton/day]	620	Cylinder Diameter [inch]	25
Primary Volatile Solids [%]	72	Hydraulic Flow Rate per Screen [gpm]	300
TWAS Flow [mgd]	1.2	Screen Opening [inch]	0.10
TWAS Total Solids [%]	5.6	Thickened Centrate	
TWAS [ton/day]	275	Avg Flow [gpm]	400
TWAS Volatile Solids [%]	78	Solids Concentration [%]	4.0
<b>Digestion Tanks</b>		<b>Advanced Dewatering Centrifuges</b>	
Number of Circular Tanks	29	Avg Flow to Centrifuges [gpm]	4,500
Capacity per Tank [ft <sup>3</sup> ]	500,000	Number	26
Total Digestion Capacity [ft <sup>3</sup> ]	14,500,000	Bowl Diameter [inch]	36
Detention Time (1 O/S) [days]	18	Bowl Height [inch]	144
Temperature [°F]	95	Feedrate per Centrifuge [gpm]	250
Loading Rate [lb VSS/ft <sup>3</sup> day]	0.095	Polymer Dose [lb/ton]	15
Percent VSS Destruction [%]	48	<b>Biosolids Storage and Loading</b>	
Gas Production (ft <sup>3</sup> /lb VSS Destroyed)	16.7	Storage Silos	
Ferrous Chloride [gpd]	12,000	Number	18
Heating System	Steam Injection	Biosolids Density [lb/ft <sup>3</sup> ]	65
Mixing System	Draft Tube w/Gas	Capacity per Silo [tons]	510
	Recirculation	Days of Storage	3.8
Digested Sludge Wet Well	Digester Z	Truck Loading Stations	
Capacity [ft <sup>3</sup> ]	500,000	Number	3
		Storage Capacity per Station [ton]	90
<b>Digester Cleanings</b>		Loading Rate [ton/hr]	175
Number of Stations	2	<b>Solids Processing Polymer Facility</b>	
Type of Screens	Inclined Static	Concentrated Polymer Storage Tanks	
Number of Screens	10	Number	7
Capacity per Screen [gpm]	300	Volume [gal]	4 @ 34,000
Type of Grit Removal	Vortex		3 @ 10,000
	Classifier/Clarifier	Total Volume [gal]	166,000
Number	2	Polymer Usage	
Capacity [gpm]	1,500	Centrifuge Dewatering [lb/day]	10,000
<b>Solids Dewatering</b>		DAF [lb/day]	1,100
Avg Digested Solids Flow [gpm]	4,100	Centrate Treatment [lb/day]	600
Max Digested Solids Flow [gpm]	5,100	Total Usage [lb/day]	11,700
Digestion Solids Concentration [%]	2.4	Polymer Mix Feed Tanks	
		Number of Tanks	4
		Capacity per Tank [gal]	15,800
		Polymer Flow @ 0.25% [gpm]	370

**Table 7.1-1  
 DETAILED DESIGN CRITERIA FOR PROPOSED FACILITIES AT JWPCP: 400 mgd PLANT CAPACITY  
 YEAR 2010 (Continued)**

Process	Capacity	Process	Capacity
<i>Solids Processing Polymer Facility (continued)</i>		<i>Washwater Systems (continued)</i>	
Polymer Use Tanks		Firewater System (Secondary & Solids Proc.)	
Number of Tanks	6	Number of Pumps	1
Capacity per Tank [gal]	2,500	Capacity per Pump [gpm]	2,500
		Lift [ft]	180
<i>Centrate Treatment</i>		Firewater System (Primary)	
Centrate Flow [gpm]	4,800	Number of Pumps	1
Centrate Solids [mg/L]	3,500	Capacity per Pump [gpm]	2,500
Centrate Solids Loading [lb/day]	192,000	Lift [ft]	140
Thickened Centrate		<i>Odor Control Facilities</i>	
Avg Centrate Concentration [%]	4.0	CFG #1, Sludge Screenings & Dewatering	
Minimum Centrate Concentration [%]	3.5	Flow [cfm]	30,000
Avg Thickened Centrate Flow [gpm]	400	Scrubber Type	Wet Scrubber
Max Thickened Centrate Flow [gpm]	460	CFG #2 and Conveyor Gallery	
Dissolved Air Flotation		Flow [cfm]	40,000
Number of Tanks	3	Scrubber Type	Wet Scrubber
Solids Loading @ Avg Rate [lb/hr-ft <sup>2</sup> ]	7.8	Sludge Storage Silos	
Overflow Rate @ Avg Flow [gpm/ft <sup>2</sup> ]	4.7	Flow [cfm]	40,000
<i>Washwater Systems</i>		Scrubber Type	Venturi
Filtration System		Centrate Treatment	
Washwater Flow [mgd]	6	Flow [cfm]	5,000
Type	Deep Bed Anthracite	Scrubber Type	Wet Scrubber
Number	4	Dissolved Air Flotation	
Length [ft]	15	Flow [cfm]	10,000
Width [ft]	15	Scrubber Type	Carbon
Media Depth [ft]	6	E-F Reactor Inlet Channel	
Surface Loading Rate [gpm/ft <sup>2</sup> ]	6.20	Flow [cfm]	5,000
Disinfection		Scrubber Type	Carbon
Number of Contact Tanks	3	G-H Reactor Inlet Tunnel	
Capacity per Tank [ft <sup>3</sup> ]	6,400	Flow [cfm]	5,000
Length per Tank [ft]	40	Scrubber Type	Carbon
Width per Tank [ft]	16	I Reactor Tunnel	
Depth per Tank [ft]	10	Flow [cfm]	5,000
Calcium Hypochlorite Dosage [mg/L]	25	Scrubber Type	Carbon
Contact Time		Central Odor Include Grit Facilities #1	
@ 1,600 gpm [min]	90	Flow [cfm]	42,000
@ 4,167 gpm [min]	35	Scrubber Type	Wet Scrubber and Carbon
Pumping System		Digester Cleaning North	
Number of Pump Stations	1	Flow [cfm]	15,000
Number of Pumps	5	Scrubber Type	Carbon
Capacity per Pump [gpm]	3 @ 500 2 @ 1,000		
Lift [ft]	231		

7-7

Chapter 7, Summary of Recommended Project



Table 7.1-1

**DETAILED DESIGN CRITERIA FOR PROPOSED FACILITIES AT JWPCP: 400 mgd PLANT CAPACITY  
YEAR 2010 (Continued)**

Process	Capacity	Process	Capacity
<i>Odor Control Facilities (continued)</i>		<i>Power Generation (continued)</i>	
E1 Skimmings		Waste Heat Recovery Boilers	
Flow [cfm]	11,000	Number of Units	5
Scrubber Type	Wet Scrubber and Carbon	Type	3-Dual Pressure 2-Single Pressure
E2/E3 Skimmings		Gross Steam Production	
Flow [cfm]	22,000	Low Pressure [lb/hr]	3 @ 8,000
Scrubber Type	Wet Scrubber and Carbon	High Pressure [lb/hr]	2 @ 35,000
Digester Cleaning #1 Modification		Steam Pressure	3 @ 23,000
Flow [cfm]	8,000	Low Pressure [psia]	3 @ 57
Scrubber Type	Carbon	High Pressure [psia]	2 @ 30
<i>Power Generation</i>		Boiler Water Treatment System	
Digester Gas Production [MMSCFD]	10.6	Number of Units	4
Digester Steam Requirement [lb/hr]	25,000-62,000	Type	2-Sodium Zeolite Softeners
Digester Gas Usage		Design Flow Per Unit [gpm]	2 @ 163 2 @ 120
Power Generation [% of Total]	95.4	Boiler Feedwater Pumps	
SIPS and Other [% of Total]	4.6	Number of Units	5
Power Generating Facility		Type	3-Single Stage 2-Multi Stage
Max Heat to 2 GTs @ TEF [MMBTU/hr]	165	Design Flow per Unit [gpm]	3 @ 70 2 @ 60
Max Heat to 1 New GTs [MMBTU/hr]	93	Total Differential Pressure	3 @ 625 2 @ 120
System Total [MMBTU/hr]	258	Motor Power	3 @ 50 HP 2 @ 7.5 HP
Gross Power Generated [MW]	25.9	Deaerator	
Parasitic Power Demand [MW]	2.9	Number of Units	1
Net Power Produced [MW]	23.0	Type	Horizontal Spray
Steam Generation [lb/hr]	62,000	Design Flow per Unit [lb/hr]	60,000
Gas Pretreatment Facility		Instrument and Plant Air System	
Digester Gas Flow [scfm]	7,600	Number of Units	4
Fuel Gas Compressors		Type	Reciprocating
Number of Units	5	Design Flow per Unit [cfm]	100
Type	3-3 Stage Recip. 2-Multi Stage Recip.	Discharge Pressure [psig]	100
Fuel Gas Discharge per Unit [scfm]	5 @ 2,800	Selective Catalytic Reduction System	
Discharge Pressure [psia]	3 @ 390 2 @ 275	Number of Units	5
Motor Power [MHP]	3 @ 1,000 2 @ 800	Type of Catalyst	Zeolite
Gas Turbines		Chemical Used	Aqueous Ammonia
Number of Units	5		
Type	3-Solar Mars T10000 2-Solar Mars T12000		
Fuel Gas Flow per Unit [scfm]	3 @ 2,380 2 @ 2,760		
Fuel Heat Input per Unit [MMBTU/hr]	3 @ 82.5 2 @ 93		

## **7.2 PROPOSED WRP EXPANSIONS**

### **7.2.1 SJCWRP**

The capacity of the SJCWRP will be expanded from 100 to 125 mgd. This expansion will be accomplished by modular additions to the primary, secondary, and tertiary treatment systems at the SJCWRP and essentially involves duplication of existing facilities. Proposed SJCWRP facilities are described in Chapter 6. Preliminary design criteria for proposed SJCWRP facilities are also presented in Chapter 6. Detailed design criteria for these facilities will be given in project level documentation for the SJCWRP expansion which will be prepared prior to project implementation.

Design and construction of proposed SJCWRP facilities are tentatively planned to begin in 2002 and 2004 respectively and the proposed facilities are tentatively expected to come on line in 2006. The actual implementation of this project may be accelerated or delayed based on actual wastewater flow development.

### **7.2.2 LCWRP**

The capacity of the LCWRP will be expanded from 37.5 to 50 mgd. This expansion will be accomplished by modular additions to the existing primary, secondary, and tertiary treatment systems at the LCWRP and essentially involves duplication of existing facilities. Proposed LCWRP facilities are described in Chapter 6. Preliminary design criteria for these facilities are also presented in Chapter 6. Detailed design criteria for proposed LCWRP facilities will be given in project level documentation for the LCWRP expansion which will precede project implementation.

Design and construction of proposed LCWRP facilities are tentatively planned to begin in 2004 and 2006 respectively and the proposed facilities are tentatively scheduled to come on line in 2008. The actual implementation of this project may be accelerated or delayed based on actual wastewater flow development.

### **7.3 BIOSOLIDS MANAGEMENT**

The Districts existing biosolids management program will be expanded to accommodate increased biosolids production from JOS facilities as a result of increased waste loads and of the implementation of full secondary treatment in the JOS. The proposed biosolids management program is described in Chapter 6.

## 7.4 RELATED PROJECTS

There are several other ongoing, independent studies which are not formally a part of the 2010 Plan. The findings of these studies will, however, affect the operation of JOS facilities, and any relevant information which becomes available will, therefore, be integrated into the 2010 Plan. The following are subjects of ongoing, independent studies:

### 7.4.1 BENEFICIAL REUSE OF RECLAIMED WATER

As a condition of the Consent Decree, the Districts agreed to use their best efforts to attain and maintain a goal of 150 mgd of beneficial reuse of reclaimed water produced at Districts' facilities by December 31, 2002. In addition, the Districts agreed to prepare a plan for the beneficial reuse of reclaimed water produced at Districts' facilities. As required by the Consent Decree, this plan shall:

- Identify and evaluate the potential for reuse of reclaimed water produced by the Districts;
- Delineate and examine the impediments to use of reclaimed water including technical, regulatory, and institutional barriers; and
- Propose a strategy for avoiding or overcoming identified impediments.

Preparation of this plan will parallel preparation of the JOS 2010 Master Facilities Plan, and as required by the Consent Decree, the plan will be submitted to the EPA and the RWQCB on or before December 31, 1995.

### 7.4.2 SEWER REHABILITATION

A number of the Districts' reinforced concrete sewers continue to undergo severe sulfide corrosion which has necessitated major sewer rehabilitation projects. As described in Section 6.13.1 of this report, the Districts continuously monitor the need for sewer rehabilitation work through the existing sewer monitoring and planning program. Necessary sewer rehabilitation projects will be identified and planned in the manner previously described and project level planning documents and environmental assessments will be prepared for each project.

### 7.4.3 LA CAÑADA WRP OUTFALL SEWER

An outfall is being constructed to tie the La Cañada WRP located in La Cañada Flintridge into the JOS. The La Cañada WRP is currently owned and operated by District No. 28, which serves a small sewer area located in the northeast portion of La Cañada Flintridge. This outfall will also provide

## *Chapter 7, Summary of Recommended Project*

---

service to local residences in District No. 34. District No. 34, which is also located in La Cañada Flintridge, currently has no local sewerage facilities. District No. 28 and District No. 34 will become members of the JOS, effective July 1, 1995, increasing the number of JOS Districts from 15 to 17. Also at that time, ownership of the La Cañada WRP, a 0.2-mgd extended aeration treatment facility, will be transferred from District No. 28 to the JOS, and the WRP will become the seventh wastewater treatment plant in the JOS. The La Cañada WRP has no solids treatment facilities, and all solids are currently transported by vacuum truck to the JOS for treatment and disposal. During summer, all of the effluent from the plant is reused at an adjacent golf course. A separate project report and an environmental document were prepared for this outfall sewer project. Construction began in March 1995. The maximum flow which these Districts are expected to contribute to the JOS is approximately 1.0 mgd. Since flow from these Districts will have a negligible effect on JOS facilities, it was not included in JOS flow projections and was not considered during the development and screening of system alternatives.

## 7.5 PROJECT FINANCING

Financing of the recommended project is presented under two categories: 1) capital and 2) operation and maintenance. Although the project costs will be incurred in future years, all amounts contained in the following discussion are in 1994 dollars.

### 7.5.1 CAPITAL FINANCING

Table 6.13-11 provided the cost estimates for each of the project alternatives plus the solids processing facilities at JWPCP. For the recommended project and solids processing facilities, these costs have been divided into upgrade and expansion components. The results are summarized in Table 7.5-1.

Table 7.5-1  
UPGRADE AND EXPANSION COMPONENTS  
OF THE RECOMMENDED PROJECT

Element	Upgrade	Expansion	Total
JWPCP (200 mgd Secondary)	\$204,800,000	\$ 0	\$204,800,000
SJCWRP (25 mgd)	0	35,300,000	35,300,000
LCWRP (12.5 mgd)	0	19,700,000	19,700,000
JWPCP (Solids Processing)	104,200,000	92,600,000	196,800,000
<b>Total</b>	<b>\$309,000,000</b>	<b>\$147,600,000</b>	<b>\$456,600,000</b>

#### JWPCP Full Secondary Treatment and Associated Solids Processing Facilities

As shown in Table 7.5-1, the capital cost of the recommended project including the associated solids processing facilities is approximately \$457 million. For purposes of preliminary financial analysis, the project can be divided into two components, upgrade (for the benefit of existing users) and expansion (for the benefit of new users). The respective costs are approximately \$309 million and \$148 million.

The upgrade portion of the project will be funded by the existing users through the Districts' Service Charge Program (annual user charge). The upgrade capital cost equates to approximately \$155 per single family home (commercial and industrial users would pay proportionally). A 1995 federal appropriation will provide a \$50 million grant for JWPCP secondary treatment facilities, bringing the net cost per single family home to \$130. This cost will be spread over the entire construction period to lessen the impact in any given year. The impact will be further reduced by the use of existing funds set aside for JWPCP secondary treatment. Additionally, the cost can be spread over an even greater number of years by utilizing long term financing, including state low-interest loans and bond financing.

**San Jose Creek and Los Coyotes WRP Expansions and Associated Solids Processing Facilities**

Both of the proposed WRP expansions plus the associated solids processing facilities provide capacity for new users. Thus, the construction costs for these projects should be passed on to these new users through the Connection Fee Program. Although the collection of connection fees and construction of the facilities parallel actual growth trends (Section 6.3.3), construction must be completed and facilities must be on-line before the new flows actually materialize. To this end, the Districts will apply for State Revolving Fund (SRF) loan funding to manage cash flows and to ensure that facilities are constructed with sufficient lead time. Ultimately, the cost of expansion will be funded through connection fees, either directly or through the repayment of SRF loan funding. As a result, the expansion-related portions of the recommended project will have no impact on existing users or the service charge which they pay.

**7.5.2 OPERATION AND MAINTENANCE FINANCING**

**Upgrade Facilities**

Regardless of whether any growth occurs, operation and maintenance (O&M) costs will increase when the JWPCP full secondary treatment facilities and associated solids processing facilities become operational. Because the operation of these facilities is not growth dependent, any increased costs will be borne by the existing users.

The projected O&M cost (present value) for these facilities is approximately \$18.5 million per year. This translates to a cost of approximately \$9 per sewage unit (single family home) per year. It should be noted that this cost will not be incurred until construction is complete. Thus, to the degree that pay-as-you-go financing is utilized, the cost of O&M will not be additive to the capital cost.

**Expansion Facilities**

There will also be an increase in O&M costs when the SJCWRP and LCWRP expansions come on line. Although the total cost will increase, the number of users will also increase proportionately. Hence, the cost per user (sewage unit) should remain the same and these facilities will have no impact on the existing service charge rate.